

## NEW CODE REQUIREMENTS

**12.7.6.1 Marking of Schedule 40 PVC and Other Non-Metallic Piping.** Schedule 40 PVC and other non-metallic piping used for ventilation, make-up, or combustion air intake shall be labeled as follows:

**(a) Throughout the entire developed length:**

1. Labels must be placed every ten feet for exposed/visible piping; or
2. Labels must be placed every three feet for concealed piping.

(b) At all changes of direction;

(c) On each side of a penetration through a partition, wall or ceiling; and

(d) The labels shall be black lettering that:

1. indicates that the piping is used for ventilation, make-up, or combustion air intake, and
2. the letters shall be sized equal to a minimum of the pipe diameter. However, for piping with a diameter exceeding two inches, said lettering does not need to be larger than two inches.

- Labels sold separately in handy shrink-wrapped rolls of 50.
- Great to keep in your truck with your stock and are easily dispensed off the perforated roll.

Order your labels today.

*Visit our online store:*

[ce.phccma.org/cgi-bin/commerce.cgi](http://ce.phccma.org/cgi-bin/commerce.cgi)



*Not actual size of stickers.*